

**DeZURIK KSL-LA SLURRY KNIFE GATE VALVE
SUGGESTED SPECIFICATION**

APPLICATION DATA 52.01-1

Page 1

June 17, 2015

First Issue



All valves shall be a Model KSL-LA Slurry Knife Gate Valve as manufactured by DeZURIK or approved equal.

Heavy-duty slurry knife gate valve shall be flat face flanged, packingless, push through gate design.

Valve shall be cast ductile iron with thick, compressed, elastomer sleeves that provide sleeve-to-sleeve seal with the valve open and sleeve to gate seat seal on both the upstream and downstream side of the valve when closed. Valve shall have a full-unobstructed port. Integral lifting lugs shall be standard on 12" and larger sizes.

Top Seal shall be provided to prevent leakage from the top of the valve and shall be one piece molded elastomer with integrated reinforcement plate.

Body shall be a two-piece casting of _____ (Ductile Iron) or (Specify). Design shall eliminate any cavities in the lower body and discharge material that could potentially prevent the valve from closing.

Gate shall be type _____ (316) (17-4 Heat Treated) stainless steel or (Specify). The gate shall fully retract out of the flowing media when in the open position and be capable of being replaced without taking the valve out of service.

Resilient Sleeves shall be capable of drip tight bi-directional shutoff to the full pressure rating of the valve. The sleeves shall act as flange gaskets on 2-8" valves. On 10" and larger valves (optional on 2-8" valves) the sleeve retainers act as flange gaskets. Resilient sleeve material shall be _____ (NR) or Specify (EPDM) (HNBR).

Cold Working Pressure valve rating shall be 100 psi (690 kPa).

Flange drilling shall be in accordance with _____ (ASME B16.5 class 150) (JIS 10) (DIN 10) (DIN 16) (ISO 7005-1/PN10) (ISO 7005-2/PN16) (BS 4504/PN10) (BS 4504/PN16) (AS2129 Table D) (AS2129 Table E) (SANS 1123-1000) or (SANS 1123-1600).

Actuation Manually actuated valves shall have _____ (chainwheel) (handwheel) on 2-10" (50-250mm) valves or (bevel gear) actuators. The manual operated (handwheel) (chainwheel) (bevel gear) superstructure shall be vertical plane style with straight legs of _____ (carbon steel) or (specify). The yoke sleeve shall be aluminum bronze. The stem shall be type 304 stainless steel. A standard locking device shall be available upon request. The lockout shall be rated to withstand the maximum output of the actuator.

DeZURIK KSL-LA SLURRY KNIFE GATE VALVE SUGGESTED SPECIFICATION

APPLICATION DATA 52.01-1

Page 2

June 17, 2015

Power actuated valves shall be furnished with _____ (cylinder) (electric motor) actuators. Cylinder actuators shall be sized to operate with _____ psi (kPa) cylinder pressure at a maximum shutoff pressure of _____ psi (kPa). The superstructure shall be vertical plane style with straight legs of _____ (carbon steel) or (specify). A standard locking device shall be available upon request. The lockout shall be rated to withstand the maximum output of the actuator.

Cylinder controls shall include _____ (solenoid valve) (speed control valves) (switches) mounted on the valve.



Need Knife Gate Valve pricing or support for your mining project? Contact us for more assistance.

Perth Branch

U2/41-45 Furnace Road

Welshpool WA 6106

Phone: +61 8 9353 2565

sales@thevalvecompany.com.au

Kalgoorlie Branch

2/69 Craig Road

West Kalgoorlie WA 6430

Phone: +61 8 9021 6668

sales@thevalvecompany.com.au

Brisbane Branch

U5/225 Queensport Road

North Murrarie QLD 4172

Phone: +61 7 3348 8636

sales@thevalvecompany.com.au

Bunbury Branch

Phone: +61 417 744 791

sales@thevalvecompany.com.au